



**GOVERNMENT OF TELANGANA  
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT  
NO OBJECTION CERTIFICATE**



From  
The Director General  
State Disaster Response and Fire Services,  
Telangana, Hyderabad.

To,  
Gogineni Balaji,  
MELUHA INTERNATIONAL SCHOOL Survey  
NO:4/20/2 HIMAYAT NAGAR VILAGE,  
MOINABAD MANDAL,  
R.R.District.,

Rc. No.311620002019Dated:04/08/2020

Sir,  
Sub: TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT -  
Issue of No Objection Certificate for Occupancy to the Non Multi storeyed Building of **Meluha School,Sy.No. 4/20/2, Himayat Nagar, Moinabad Mandal, R.R.District/- Himayathnagar/Moinabad/Rangareddy**, Hyderabad - Regarding.



Ref: 1. Acknowledgement No311620002019dt.04/08/2020  
2. Inspection Committee Report, Acknowledgement No: 311620002019

\*\*\*\*\*

1. The Multi Storeyed Building Inspection committee, vide reference cited (2) have inspected the Non Multi Storeyed Building of **Meluha School,Sy.No. 4/20/2, Himayat Nagar, Moinabad Mandal, R.R.District/- Himayathnagar/Moinabad/Rangareddy** and submitted the following report.

2. The above building was constructed without obtaining the Provisional Noc from this department and now the builder submitted application for issuance of No Objection Certificate for occupancy to the existing bulding of **Ground, 3 Floors**, with a height of **13.90 Meters** for **EDUCATIONAL B-1 Schools up to senior secondary level**.

3. Open Spaces : The builder provided the following open spaces all around the building.

Sl.No	side	Open space Required as per Supreme Court's order on W.P.No.483 of 2004	Open space Provided
1	North	6.00	6.00
2	South	6.00	6.00
3	East	6.00	6.00
4	West	6.00	6.00
5	Front Direction	East	

4. Means of Access :

Sl. No	Gate Width As per NBC 2016	Required	Provided
1	Entry gate width	6.00	6.00
2	Exit Gate Width	6.00	6.00
3	Entry Gate Head Clearance	4.50	4.50
4	Exit Gate Head Clearance	4.50	4.50

5. Travel Distance

Sl. No.	Item / Description	Required (Not More than in Mtrs.)	Provided
1	Farthest point ( Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	28.00
2	The Dead end of the corridor length in exit access. ( 6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	3.00

6. Stair Cases (As per NBC 2016)

Sl.no.	Type of staircases	Width (In Mtrs)	No of staircases	Floors from	Floors to
1	Internal staircases	1.65	1	Ground	2nd Floor
2	Internal staircases	1.20	1	2nd Floor	Terrace

Principal  
**Meluha School**  
Sy No: 4/20/2 Himayat Nagar (V),  
Moinabad Mandal, Rangareddy

*G. Balaji*  
Principal  
**Meluha School** Moinabad Mandal, R.R. Dist  
Sy No: 4/20/2, Himayathnagar (V),  
Moinabad (M), Ranga Reddy